

Temporary Tents and Membrane Structures

Synopsis from the *International Fire Code*, 2012 Edition, Chapter 31

For ALL temporary structures

- Shall not be more than 180 days
- Must be adequately anchored
- Fabric must be flame resistant per NFPA 701 and have a permanent label
- No combustible materials inside – hay, straw or wood shavings
- No open flame devices within the structure unless inspected/approved by KFD
- 5 lb ABC fire extinguisher in each booth or a public fire extinguisher station every 75'
(All FOOD BOOTHS must provide, and keep accessible, their own 5 lb ABC fire extinguisher; KAAHC will provide fire extinguishers for public use for all other booths.)
- Class K extinguisher if deep frying with a capacity larger than 1 gallon of oil
(available at Tyler Industrial)
- LP-gas containers 10-500 gallons – outside of structure and separated from appliance(s) by at least 10'
- Heat producing appliances must be 3' or greater from any fabric or combustible material
(this means you must have your cooking appliances 3 feet away from all walls of your/your neighbor's tent.)

Open Flames (Candles)

Synopsis from the *International Fire Code*, 2012 Edition, Chapter 3

- With approval
- Cannot be passed from one person to another
- Prohibited in areas where people stand – aisles or exits